

المواصفة القياسية السورية رقم ١٩٧٩/١٥٤ SNS154/1979
L P G (Butane- Propane Mixture)

SPECIFICATIONS	REQUIREMENTS	TEST METHODS
C3 % Wt. Max.	25	ASTM D-2163/70
C4 % Wt. Max.	75	ASTM D-2163/70
C5 and heavier %Wt.Max.	2 Winter 3 summer	ASTM D-2163/70
Vapor pressure at 50 °C (kg/Cm ²)Max.	8	ASTM D-1267/67
Total Sulphur % Wt. Max	0.01	ASTM D-2784/69 ASTM D-1266/70
Mercaptan Sulphur % Wt.	0.003-0.008	Ip 272/71T
Hydrogen sulphide % Wt. Max.	0.002	Ip 272/71T
Dryness	Free from entrained water	ASTM D-2713/70
95% Boiling point at 760 mm Hg Max. °C	2.3	ASTM D-1873/64